

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


No.F.6 DFS/MS/School/2021/SZ/ 930

Dated: 12/11/2021

**FIRE SAFETY CERTIFICATE**

Certified that Kendriya Vidyalaya located at Sector -2, R.K Puram, New Delhi 110022 comprised of Ground plus Three upper floors owned/occupied by Kendriya Vidyalaya was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2012/School/3107 Dated 27/08/2012. The said premises was re-inspected by officer concerned of this department on 01/11/2021 in presence of Sh. Awadhesh Dubey (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building is fit for occupancy class "Educational Building Group - B" with effect from 12/11/2021 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 12/11/2021 at New Delhi by



(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER

Copy to: -

1. The Principal, Kendriya Vidyalaya at Sector -2, R.K Puram, New Delhi 110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

*Blair*  
23/11/2021

*original kept  
in Principal's  
Almirah*

केन्द्रीय विद्यालय  
सेक्टर-2, रा.कु.पु. नई दिल्ली-110022  
आगत संख्या... 31  
दिनांक... 23/11/2021

*Sm's?*